

Public Works report for the month of January 2025

Water numbers sold for January 2025

Treated water produced 4,684,000 Water sold 2,126,993- Back-washes 217,000 leaks WATER 20,000 = LOSS EST. @ 47.0 %. Rain for January 8.5", Plant ran 3 days 24 hr cycles

Water Treatment plant,

1. Service line inventory updating in progress
2. Replaced pump 18th St. pump station due to failure.
3. Repaired leaks on chemical feed pumps
4. Surveyed water plant for Raw water tank placement
5. Coast Guard hill pump station, on hold due budget shortfalls
6. Vista Pump station, we'll wait to fund replacement in next budget cycle.

Water distribution leaks repair:

1. Lots of locates for fiber drops
2. Leak 2" Deedy St. pump station
3. Service repair Deedy & 13th
4. Leak repair 2" @ Washington & 20th
5. Service line repair on Wood-glen

Waste Water plant: Op's:

1. Pinehurst sewer lift-station went down due to controls / floats.
2. Arizona Lift station replacement, is in manufacturing @ Smith & loveless 90-120 days out. RFP for install in the works.
3. Lift station degrease floats, lots of grease

City shop yard

1. Dump runs to remove old debris; work will continue until its completed
2. Vehicle Pm's

Streets, replaced several stop signs and post, cleaned gutters

Parks 3 load of gravel delivered for Battle Rock lower parking area and Buffington

PW Works Equipment PM's

Small equipment PM's.

New rims and tire's needed for Backhoe in the works